


## ALTIVAR® 61 GRAPHIC DISPLAY TERMINAL




### Description and Operation

- A** Display Status: Displays default settings—the drive's state, active control channels, frequency reference, and LOC/REM (T/K key status). The Display Status content can be configured.
- B** Menu line: Displays the name of the current menu or submenu.
- C** Submenus: Lists the submenus of the current menu.
- D** Scroll boxes: Indicates (by arrow direction) whether there are additional submenus or levels to access. A blank box indicates that there are no additional submenus or levels to access.
- E** Status line displays the functions assigned to function buttons F1–F4. Code = F1, << = F2, >> = F3, and T/K = F4. See the descriptions below.
- F** Function buttons—  
**F1** displays the code of the selected parameter or contextual Help.  
**F2** provides navigation to the left / returns to the previous menu or submenu  
**F3** provides navigation to the right / advances to the next menu or submenu  
**F4** command and reference via the terminal
- G** Stop/Reset button—stops the drive controller and resets the faults
- H** ESC button—exits a menu or parameter, or cancels a value to return to the previous value in the memory
- I** Run button—runs the motor with the current setting. Starts the drive controller if in HMI command mode.
- J** Navigation button/dial—pressing the button saves a value or enters a menu or parameter. Turning the dial clockwise increases a value. Turning the dial counter-clockwise advances to the next menu item or line, or decreases the reference (if terminal control is active).
- K** FWD/REV button—reverses the rotation direction of the motor (if configured to allow reverse for HMI command mode).

NOTE: Refer to the Altivar 61 (ATV61) programming manual for detailed information about the display terminal operations.

## PROGRAMMING PARAMETERS

Example of accessing the acceleration ramp setting



### Changing a parameter



1. Use the navigation dial to vertically scroll the DRIVE MENU list, press ENT (navigation button) to select the submenu.
2. Select the parameter to change and press ENT.
3. Use F1 and F2 to scroll horizontally, then select the digit to change (the digit is highlighted).
4. Turn the navigation dial clockwise to increase the digit or counter-clockwise to decrease the digit.
5. Press ENT to save the change or press the ESC button to cancel the change.

## MACRO CONFIGURATION PARAMETERS


Input/output	[Start/Stop]	[Gen. Use]	[PID regul.]	[Network C.]	[Pumps.Fans]
A11	[Ref.1 channel]	[Ref.1 channel]	[Ref.1 channel] (PID reference)	[Ref.2 channel] ([Ref.1 channel] = integrated Modbus)	[Ref.1 channel]
A12	[No]	[Summing ref. 2]	[PID feedback]	[No]	[Ref.1B channel]
AO1	[Motor freq.]	[Motor freq.]	[Motor freq.]	[Motor freq.]	[Motor freq.]
R1	[No drive fit]	[No drive fit]	[No drive fit]	[No drive fit]	[No drive fit]
R2	[No]	[No]	[No]	[No]	[Drv running]
LI1 (2-wire)	[Forward]	[Forward]	[Forward]	[Forward]	[Forward]
LI2 (2-wire)	[Fault reset]	[Reverse]	[Fault reset]	[Fault reset]	[Freewheel]
LI3 (2-wire)	[No]	[No]	[PID integral reset]	[Ref. 2 switching]	[Ref 1B switching]
LI4 (2-wire)	[No]	[Fault reset]	[2 preset PID ref.]	[Forced local]	[Fault reset]
LI5 (2-wire)	[No]	[Torque limitation]	[4 preset PID ref.]	[No]	[No]
LI6 (2-wire)	[No]	[No]	[No]	[No]	[No]
LI1 (3-wire)	Stop	Stop	Stop	Stop	Stop
LI2 (3-wire)	[Forward]	[Forward]	[Forward]	[Forward]	[Forward]
LI3 (3-wire)	[Fault reset]	[Reverse]	[Fault reset]	[Fault reset]	[Freewheel]
LI4 (3-wire)	[No]	[No]	[PID integral reset]	[Ref. 2 switching]	[Ref 1B switching]
LI5 (3-wire)	[No]	[Fault reset]	[2 preset PID ref.]	[Forced local]	[Fault reset]
LI6 (3-wire)	[No]	[Torque limitation]	[4 preset PID ref.]	[No]	[No]
Option cards					
LI7 to LI14	[No]	[No]	[No]	[No]	[No]
LO1 to LO4	[No]	[No]	[No]	[No]	[No]
R3/R4	[No]	[No]	[No]	[No]	[No]
AI3, AI4	[No]	[No]	[No]	[No]	[No]
RP	[No]	[No]	[No]	[No]	[No]
AO2	[I motor]	[I motor]	[I motor]	[I motor]	[I motor]
AO3	[No]	[No]	[PID Output]	[No]	[No]
Graphic display terminal keys					
F1 key	[No]	[No]	[No]	[No]	[No]
F2, F3 keys	[No]	[No]	[No]	[No]	[No]
F4 key	[T/K] (Control via graphic display terminal)	[T/K] (Control via graphic display terminal)	[T/K] (Control via graphic display terminal)	[T/K] (Control via graphic display terminal)	[T/K] (Control via graphic display terminal)

In 3-wire control, the assignment of inputs LI1 to LI7.

## TYPICAL CONNECTIONS



NOTE: The graphic display terminal is standard on the ATV61 high horsepower (hp) drive controllers and is optional on the low hp drive controllers. ATV61 low hp drive controllers are equipped with a 7-segment, 4-digit integrated display terminal.



NOTE:

- The key drive settings to monitor are highlighted in yellow. Refer to the ATV61 programming manual for additional programming instructions.
- All menu levels are accessible through the Expert access level.

Electrical equipment should be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

© 2006 Schneider Electric All Rights Reserved

